RESOLUTION NO. 2004-196

A RESOLUTION OF THE LODI CITY COUNCIL AUTHORIZING THE NON-COMPETITIVE PURCHASE OF MOUNTING PADS FOR TRANSFORMERS, MODULE ENCLOSURES, AND SWITCHGEAR BOXES

WHEREAS, Lodi Municipal Code §3.20.070 authorizes dispensing with bids for purchase of supplies, services, or equipment when it is in the best interest of the City to do so: and

WHEREAS, the Electric Utility Department's Engineering Division has issued work orders requiring installation of padmounted transformers and module enclosures at three new residential developments in Lodi and at a professional office on Kettleman Lane. Additionally, three padmounted switchgear boxes are intended for installation in the new subdivisions; and

WHEREAS, all will require use of the fiberglass pads listed below and illustrated in the attached Exhibit A for proper installation:

	Transformer Box Pad #TX423820	Mod. Enclos Box Pad #TX484232	Padmtd Switch Box Pad #SG866632	
Dental Offices, 1745 W. Kettleman Lane		3	0	
Winchester Woods, Winchester Dr n/o Harney	1	1	T T	
Vintage Oaks, Lower Sac n/o Kirsten Ct	2	2	1	
Vintners Square, Lower Sac & Taylor Rd	5	3	1	
Reserve inventory		1		

WHEREAS, the Engineering Division has also determined that the fiberglass pads manufactured by ProGlass, Inc. offer superior strength, stability, and durability and has approved only ProGlass pads for use in the City's electric distribution system. ProGlass sells directly to utilities and is a supplier to SMUD, Southern California Edison, and LADWP, as well as Lodi Electric.

NOW, THEREFORE, BE IT RESOLVED that the City Council of the City of Lodi does hereby approve the non-competitive purchase of mounting pads for transformers, module enclosures, and switchgear boxes from ProGlass Inc., of Wauna, Washington, in the amount of \$12,064.98.

Dated: October 6, 2004

I hereby certify that Resolution No. 2004-196 was passed and adopted by the City Council of the City of Lodi in a regular meeting held October 6, 2004, by the following vote:

AYES:

COUNCIL MEMBERS - Beckman, Hitchcock, and Howard

NOES:

COUNCIL MEMBERS - None

ABSENT:

COUNCIL MEMBERS - Land and Mayor Hansen

ABSTAIN:

COUNCIL MEMBERS - None


SUSAN J. BLACKSTON

City Clerk




Transformer Box Pads

TX Series w/Optional Lids





TX423820




TX423830

Stock Number	Depth "D"			
TX423820	20"			
TX423824	24°			
TX423830	30"			







NOTICE. This decorated (and all of the information, data and designs contained horize) in the property of Power Glass, Inc., dee PROCEASS, and is to be used only as reference to work proposed or state acted by PROCEASS. This confidential information must not be copied, displaced, or used without the experted permission of written consent of PROCEASS. These decertings must be returned intermediately upon request. Discontinual consented at the intersection of properties adjacent planes.


PROGLASS, INC.

P.O. Box 581 - Wauna, WA 98395 www.proglassinc.com Email: proglass@msn.com Phone: 253-884-4008 Fax: 253-884-5064



Transformer Box Pads

TX-TI Series



top.
The discusses had all of the referencing, due and danger commendatives in the report of Frank less, the, file, files, the to be one only proposed or nonementary PROVIDES. The confidental information and performance where the defining of the confidental information of the co

PROGLASS, INC.

P.O. Box 581 - Wauna, WA 98395 www.proglassinc.com Email: proglass@msn.com Phone: 253-884-4008 Fax: 253-884-5064




Switchgear Box Pads

Features:

- Non-Conductive and Corrosion Resistant

- High Strength-to-Weight Ratio 4-1/2" Perimeter Lip at Base for Stability Internal Reinforced Ribs for Resistance to Deflection
- Custom Sizes Available for ANY Size Switchgear



	Тор		Opening		Base		Depth	
Stock Id	A	8	C	D	E	F	G	
SG483030	48"	30:	42.5*	24.5"	60"	41.5*	30°	
SG563936	58"	39°	44"	27-7/8"	50°	67"	36"	
SG704432	70*	44*	60″	307	81.5*	55.5*	32"	
SG716536	71*	65'	56"	50"	77"	71°	36°	
SG767440	76°	74*	64"	62"	87"	86"	40°	
SG787332	78"	73*	68"	58.5"	90"	85.5*	32'	
SG866632	867	66*	71"	51*	96"	78"	32"	
SG867832	86"	78°	71"	63"	97.5"	89.5"	32*	

SOFER. This document (and all of the information, data and designs escalated horizin) is the property of Power Claus, Inc., the PROSEASS, and is to be east only in reference to work proposed or contracted by PROSEASS. This confidential information make no be copied, displicated, or cond without the represent geometric or written concept of PROSEASS. Transfer used to extend the retained intercolately upon request. Disservings (inches) are restaured or the intersection of projected adjocute plants.

P.O. Box 581 - Wauna, WA 98395 www.proglassinc.com Email: proglass@msn.com Phone: 253-884-4008 Fax: 253-884-5064

2.00